

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

VICTOR H. CUEVAS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES
CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

RECEIVED
12/23/09

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

RAYMOND S. CHAN, C.E., S.E.
INTERIM GENERAL MANAGER

ITW Ramset
700 High Grove Bl
Glendale Heights, IL 60139

Attn: Dave Jablonski
(800) 726-7386

RESEARCH REPORT: RR 25638
(CSI 05090)

BASED UPON ICC EVALUATION SERVICE
REPORT NO. ESR-2174

REEVALUATION DUE DATE:
December 1, 2010
Issued Date: December 1, 2009
Code: 2008 LABC

GENERAL APPROVAL – GYP-FAST™ fasteners used to attach gypsum sheathing to metal studs.

DETAILS

The above assemblies and/or products are approved when in compliance with the description, use, identification and findings of Evaluation Report No. ESR-2174, dated May 1, 2008, revised January 2009 of the ICC Evaluation Service, Incorporated. The report, in its entirety, is attached and made part of this general approval.

The parts of Evaluation Report No. ESR-22174 marked by an asterisk are modified or deleted by the Los Angeles City Building Department from this approval.

The approval is subject to the following conditions:

- 1 Allowable negative transverse loads on sheathing attached to metal studs are limited to the value noted in Table 1 of this report.
2. Fasteners are manufactured, identified and installed in accordance with this report.
3. An approved exterior wall covering and weather-resistive barrier are required over the system in accordance with 2008 Los Angeles City Building Code.

RR 25638
Page 1 of 2